



22EWXMCOL001-7

ICOOOL CHEMICAL CO., LTD

CERTIFICATE OF ANALYSIS

Customer Name	UNI REFRIGERACION COLOMBIA SAS	
Product Name	REFRIGERANT R134A	
P.I. No.	E22XMCOL001	
Analysis Date	2022/9/20	
GUARANTEED SPECIFICATIONS		
Analyte	Specifications	Results
Appearance	Colorless, Transparent	Colorless, Transparent
Smell	Odorless	Odorless
Purity, %	≥ 99.8	99.96
Water, %	≤ 0.001	0.0008
Acidity, %, as HCL	≤ 0.0001	≤ 0.0001
High boiling residue, % by volum	≤ 0.01	0.0008
Chloride content (CL)	≤ 3	PASS
Non condensable gas in vapour, % by volume @ 25°C	≤ 1.5	0.58
Conclusion	Quality product	

艾科新材料有限公司
ICOOOL CHEMICAL CO.,LTD.

姜慧明